



U. S. Department of Homeland Security
United States Coast Guard
Certificate of Approval

Coast Guard Approval Number: 164.136/32/0

Expires: 15 June 2011

FIRE DOORS (IMO)

R&M SCHIFFSISOLIERUNG
UND-AUSBAU GMBH
PETRIDAMM 11C 18146
ROSTOCK GERMANY

B-15 single leaf hinged integrated steel door with kick-out panel and louver approved as meeting the IMO FTP Code Annex 1, Part 3.

Maximum door leaf dimensions 861 mm wide by 1979 mm high, kick-out panel 398 mm wide by 498 mm high (426 mm wide by 528 mm high on opposite side) with louver, 420 mm wide by 280 mm high.

Identifying Data: DIFT reports No. PG 10696, Serial No. 7660 dated 12 July 2000, No. F10739a, Serial No. 7223 dated 7 June 1999, No. F10766, Serial No. 7298 dated 16 August 1999, R&M Drawings EP/IB15:001/1-5 dated 31 May 2000, EP/IB15:002/1-5, dated 15 May 2000, EP/IB15:003/1-5 dated 17 May 2000, EP/IB15:004/1-5, dated 19 May 2000, EP/IB15:005/1-5 dated 15 May 2000, and USCG letters dated 21 June 2001 and 15 June 2006.

Follow-Up Program: DIFT

Approval valid only for products from above factory location.

Supersedes and extends Appr. No. 164.136/32/0 dated 21 June 2001.

*** END ***

THIS IS TO CERTIFY THAT the above named manufacturer has submitted to the undersigned satisfactory evidence that the item specified herein complies with the applicable laws and regulations as outlined on the reverse side of this Certificate, and approval is hereby given. This approval shall be in effect until the expiration date hereon unless sooner canceled or suspended by proper authority.



GIVEN UNDER MY HAND THIS 15th DAY OF
JUNE 2006, AT WASHINGTON D.C.

J. G. LANTZ
Chief, Lifesaving and Fire Safety Standards Division
BY DIRECTION OF THE COMMANDANT